



## ELECTRICAL SPECIAL CONNECTION REQUIREMENTS & APPLICATION FORM

Cayman Islands Government  
Planning Dept., Building Control Unit  
P.O. Box 31206  
Grand Cayman KY1-1205  
CAYMAN ISLANDS  
Phone (345) 769-7526 Fax: (345) 769-2228

### The following items must be installed and completed prior to applying for an electrical special connection.

1. The electrical service(s), associated feeders and equipment shall be completely installed (e.g. panels, transformers, wiring methods, wiring etc.).
2. All electrical equipment such as, panels boards, motor controllers, breakers and disconnecting means pertaining to the special connection must be properly identified as per NEC 110.22 and NEC 408.4.
3. Electrical rooms shall be provided with lighting as per NEC 110.26 (D), (lighting must be fed from a permanent service).
4. Lighting must be provided at or near all electrical equipment(s) that require connection for testing.
5. Doors leading into electrical rooms must be clearly identified with permanent electrical warning signs and capable of being locked.
6. Where applicable; electrical doors shall be equipped with panic hardware as per NEC 110.26.
7. Where applicable; a Ground Fault Protection Interrupter (GFPI) test shall be performed in accordance with the NEC 230.95 and the result must be submitted with this special connection request application.
8. All electrical equipment requiring the special connection must be installed and ready to be commissioned (e.g. elevators, fire pump, air-conditioning equipment etc.).
9. The building(s) must be substantially dried-in (to be determined by the Building Inspector).

**Comments:**


**Note:**

- a. A special connection does not constitute the right for additional electrical equipment to be energized without the required inspections and approval as per the Cayman Islands Electricity Regulations.*
- b. Compliance with the above items does not necessarily constitute automatic approval of a special electrical connection.*
- c. A lock and tag-out procedure must be in force for the period of the special connection unless otherwise approved by the Chief Electrical Inspector or the Senior Electrical Inspector.*

**Please fill out the form on the backside of this application when applying for an electrical special connection.**

I/We hereby request a special electrical connection for the installation listed below.

<b>Applicant:</b>			Phone No:
Address:			Fax No:
Block:	Parcel:	File No:	Permit No:
<b>Electrical Contractor:</b>			Phone No:
Trade & Business Lic. No:		Expires:	Fax No:
Electrical Lic No:	Expires:	Email:	

**The reasons for this request are as follows:**

---

---

---

---

---

---

---

---

**PLEASE NOTE**

Special connections are issued pursuant to Regulation 56 of the Electricity Regulations (2005 Revision). The installation shall be disconnected from the source of electrical energy upon the expiration of the period set out in Regulation 36 to 38, unless a final certificate has been issued pursuant to regulation 35 prior to expiration of the period.

The approval of a Special Connection does not grant authority to occupy a building prior to the issuance of a Certificate of Occupancy. Failure to comply with this condition will result in the immediate disconnection of the Electrical Source.

Electrician on behalf of Contractor (print and sign)	Electrical License No	Date
--	-----------------------	------

**OFFICIAL USE ONLY**

Having conducted the necessary electrical inspections this application is **APPROVED** , **DISAPPROVED**  subject to the following conditions:

---

---

---

---

---

---

---

---

\_\_\_\_\_  
Electrical Inspector Date

\_\_\_\_\_  
Chief Building Control Officer Date

**Please refer to the requirements on the front of this application before applying for an electrical special connection.**